

Fire Protection

	YES	N/A	LOI OBSERVED
1.	<input type="checkbox"/>	<input type="checkbox"/>	Combustible scrap, debris, and waste materials (oily rags, etc.) are stored in covered metal receptacles and removed from the worksite promptly
2.	<input type="checkbox"/>	<input type="checkbox"/>	Approved containers and tanks are used for the storage and handling of flammable and combustible liquids
3.	<input type="checkbox"/>	<input type="checkbox"/>	All flammable liquids are kept in closed containers when not in use (i.e: parts cleaning tanks, pans, etc.)
4.	<input type="checkbox"/>	<input type="checkbox"/>	Bulk drums of flammable liquids are grounded and bonded to containers during dispensing
5.	<input type="checkbox"/>	<input type="checkbox"/>	All connections on drums and combustible liquid piping, are vapor and liquid tight
6.	<input type="checkbox"/>	<input type="checkbox"/>	Storage rooms for flammable and combustible liquids have explosion-proof lights
7.	<input type="checkbox"/>	<input type="checkbox"/>	Storage rooms for flammable and combustible liquids have mechanical or gravity ventilation
8.	<input type="checkbox"/>	<input type="checkbox"/>	Liquefied petroleum gas is stored, handled, and used in accordance with safe practices and standards
9.	<input type="checkbox"/>	<input type="checkbox"/>	"NO SMOKING" signs are posted on liquefied petroleum gas tanks
10.	<input type="checkbox"/>	<input type="checkbox"/>	liquefied petroleum storage tanks are guarded to prevent damage from vehicles
11.	<input type="checkbox"/>	<input type="checkbox"/>	All solvent wastes and flammable liquids are kept in fire-resistant, covered containers until they are removed from the worksite
12.	<input type="checkbox"/>	<input type="checkbox"/>	Fuel gas cylinders and oxygen cylinders are separated by distance, and fire-resistant barriers, while in storage
13.	<input type="checkbox"/>	<input type="checkbox"/>	Fire extinguishers selected and provided for the types of materials in areas where they are to be used: Class A Ordinary combustible material fires; Class B Flammable liquid, gas or grease fires; Class C Energized-electrical equipment fires
14.	<input type="checkbox"/>	<input type="checkbox"/>	Appropriate fire extinguishers are mounted within 75 feet of outside areas containing flammable liquids, and within 10 feet of any inside storage area for such materials
15.	<input type="checkbox"/>	<input type="checkbox"/>	Fire extinguishers are free from obstructions or blockage
16.	<input type="checkbox"/>	<input type="checkbox"/>	All Fire extinguishers are serviced, maintained and tagged at intervals not to exceed 1 year
17.	<input type="checkbox"/>	<input type="checkbox"/>	All fire extinguishers are fully charged and in their designated places
18.	<input type="checkbox"/>	<input type="checkbox"/>	"NO SMOKING" signs are posted where appropriate in areas where flammable or combustible materials are used or stored
19.	<input type="checkbox"/>	<input type="checkbox"/>	Safety cans are used for dispensing flammable or combustible liquids at a point of use
20.	<input type="checkbox"/>	<input type="checkbox"/>	Spills of flammable or combustible liquids are cleaned up promptly
21.	<input type="checkbox"/>	<input type="checkbox"/>	Storage tanks are adequately vented to prevent the development of excessive vacuum or pressure as a result of filling, emptying, or atmosphere temperature changes
22.	<input type="checkbox"/>	<input type="checkbox"/>	Storage tanks are equipped with emergency venting that will relieve excessive internal pressure caused by fire exposure
23.	<input type="checkbox"/>	<input type="checkbox"/>	"NO SMOKING" rules enforced in areas involving storage and use of hazardous materials

Comments:

<hr/> <hr/> <hr/>

Contractor: _____

P.O. Number: _____

Area/Location: _____

Project No: _____

Print Name_____
Signature_____
Date